



# SCI/NHBC Certification

## Saint-Gobain Offsite

# IntraSTACK Light Steel Frame System

### SCI / NHBC Stage 1 System Certification

The Steel Construction Institute has assessed the structural aspects of the IntraSTACK System for Stage 1 – System Certification and confirms that it is suitable for use in the construction of dwellings in accordance with NHBC Standards Chapter 6.10 “Light steel framing”.

The system has been assessed for residential buildings up to 15 storeys high. As its basic components the system uses cold rolled galvanized C-sections for wall studs, floor joists and roof joists.

To confirm validity, please visit the SCI Certification and Assessment website at [www.sci-assessed.com](http://www.sci-assessed.com).



Product ID: 20270920  
End Date: 20<sup>th</sup> September 2027

Dr Graham Couchman, Chief Executive  
The Steel Construction Institute